STANDARD DRAWING

REQ. PER UNIT	USED ON MODEL	ASS'Y. NO.	DATE	DD122	A
	TSTE-10K		6-17-65		



SCHEMATIC OF BRIDGE
TO APPEAR ON UNIT

RATINGS FOR 60 THRU 400 CPS *

	PIV	INPUT VRMS	OUTPUT VDC	SURGE AMPS.
NOMINAL		115	100V	—
	AUTOMATIC PROTECTION			
MAXIMUM		130	116	25A 8MS

* SINUSOIDAL INPUT, RESISTIVE OR INDUCTIVE LOADS

CURRENT RATING BY DUTY CYCLE † (20°C)

DUTY CYCLE	CONTINUOUS	3/4	1/2	1/4	1/10
MAX. CURRENT RATING (AMPS)	1.8	2.4	3.6	7.2	7.5
MAX. PULSE LENGTH (SEC.)	CONTINUOUS	115	100	43	20

† DUTY CYCLE = $\frac{\text{PULSE LENGTH}}{\text{PULSE LENGTH + "OFF" TIME}}$



TYPICAL CIRCUIT

TC - TRANSIENT CONTROL
(BUILT IN)

SYM	DESCRIPTION	DATE	CH. NO.	DRAFTS	CHECKER	ENG. APP.
A	ADDED 'REF' TO .312, .548 & 1.087 DIM. REV. SCHEM STAMP NOTE & ADDED TYP. CKT. TO SCH.	7-7-66	K6505	JB	JCB	JC
Ø	ORIGINAL RELEASE FOR PRODUCTION.	6-17-65	—	HLA		

UNLESS OTHERWISE SPECIFIED
DIMENSIONS ARE IN INCHES AND INCLUDE
CHEMICALLY APPLIED OR PLATED FINISHES

SCALE —

TOLERANCES
DECIMALS .X ±.05 .XX ±.01 .XXX ±.005
FRACTIONS ± 1/64
ANGLES ± 0° 30'

CODE C

S401-281
(A46502-003)

REQ.	ITEM	PART NO.	DESCRIPTION	SYMBOL
		—		

STOCK SIZE —

MATERIAL —

TYPE & TEMPER — | HEAT TREAT. SPEC. —

FINISH & SPEC. NO. —

THE TECHNICAL MATERIEL CORP.
MAMARONECK. NEW YORK

RECTIFIER
SILICON BRIDGE

DRAWN	CHECKED	FINAL APPROVAL
H. AUSTIN	JCB	MV 6/20/65

ELEC. DES. APP.	MECH. DES. APP.		
	JCB 6-18-65	DD122	A

TMC FORM 108-A

REPROVEL NO. 440H 23845